

**CORRIGENDUM 1 TO THE TENDER TOWARDS SUPPLY AND INSTALLATON OF
2 X33KWp ROOFTOP SOLAR INSTALLATION AT BLOCKS B2 AND B3,
VALAGERAHALLI PHASE 6, KENGERI, BENGALURU DATED 04/02/2022**

S.No	Page No. in Tender	Clause as per RFP	CORRIGENDUM
1	Page 6 - Point 4 of Eligibility Criteria	Should have registered office in Bengaluru/ Karnataka with functioning service set up in Bengaluru	Clause is deleted.
2	Page 6 - Point 5 of Eligibility Criteria	Address and contact details of the office and service centre in to be furnished. Copy of document proof of local address i.e lease agreement of the firm entered with landlord, tax paid receipt or GST registration has to be submitted. The same may be inspected by Bank officials.	Address and contact details of the office and service centre in Bengaluru to be furnished. Copy of document proof of local address i.e. lease agreement of the firm entered with landlord, tax paid receipt or GST registration has to be submitted. The same may be inspected by Bank officials.
3	Page 4 & Page 28- Completion Period	60 days from the date of issue of work order(including mobilization period)	90 days from the date of issue of work order (including mobilization period)



S.No	Page No. in Tender	Clause as per RFP	CORRIGENDUM
4	Page 85 - Technical Data Sheet - SAFETY	Galvanic Isolation at input & Output through transformer.	Inverter Isolation to be of transformer less type.
5	Page 79 - Annual Generation Guarantee	2nd Year : 99.0% of 1st Year Generation 3rd Year : 98.5% of 1st Year Generation 4th Year : 98.0% of 1st Year Generation 5th Year : 97.5% of 1st Year Generation	As per MNRE degradation clause : PV modules shall be warranted for their output peak watt capacity, which should not be less than 90% at the end of 10 years and 80% at the end of 25 years.

